



SUNSHINE COAST REGIONAL DISTRICT

Question and Answers # 2

Request for Proposal No. 2261322

Engineering Air Roof Top Unit Replacement

Date: November 15, 2022

Item No. 1

Question: for the Condensing Unit Cage should the cage be chain link fence? Is 6 feet high enough?

Answer: Yes, it should be chain link. 6' Is fine provided the chain link fence is not up against the 32" block retaining wall on the rear side of the fence.
