



SUNSHINE COAST REGIONAL DISTRICT

Question and Answers #1
Request for Proposal No. 2534501
Wharf Repairs – Keats Island

Date: May 30, 2025

Item No.1

Question: Could we please have the sounding measurements for the wharf structure?

Answer: The sounding measurements for Keats Island (2024.02.23) are as follows:

Location	Depth (mm)
2C	4572
3C	6401
7C	7315
14A	8941
14F	9144
20A	13106
20F	13106
*note: measurements from mudline to top of structure deck.	

The information provided above is accurate to the best of our knowledge. However, it is the Proponent/Contractor's responsibility to verify.
