



## HEALTH PROTECTION

# PERMIT TO OPERATE

### A Water Supply System

**Purveyor: Sunshine Coast Regional District**

**Facility Name: SCRD North Pender Harbour Water Service Area**

### Conditions of Permit

1. Provide long-term plans for source, treatment, and distribution system improvements.
2. Minimum bacteriological sampling frequency is semi-monthly from 7 distribution sites and from the 2 source sites.
3. Provide and make public, within 6 months of the end of the calendar year, an Annual Report.

**March 26, 2007**  
**Effective Date**  
**March 31, 2014**  
**Revised Date**

\_\_\_\_\_  
**Darren Molder, Drinking Water Officer**

**This permit must be displayed  
in a conspicuous place and is not transferable**