

July 14, 2025

Sunshine Coast Regional District,
1975 Field Road,
Sechelt,
B.C., V0N 3A1

Attention: Pria Giri

To Whom It May Concern:


**Watermain Upgrade in Panorama Drive area, North Pender Harbour, SCR D, BC
Water Supply System Construction Permit VCH-25-649**

I refer to your request to extend the validity period for Construction Permit VCH24-572.

Please find enclosed a Construction Permit issued under Section 7 of the Drinking Water Protection Act authorizing your waterworks construction. This Permit extends the validity period of the earlier Permit # VCH-24-572 dated July 16, 2024. There is no change to the terms and conditions except that the validity of the permit is extended for one year from date of this permit.

If you have any questions regarding this Permit, do not hesitate to contact me at the phone number or e-mail address noted below.

Yours truly,



Chris Keung, P. Eng.
Public Health Engineer
telephone: 604-219-7142
e-mail: christopher.keung@vch.ca

cc: Michael Nguyen, DWO, VCH

Water Supply System Construction Permit

No. VCH – 25 – 649

TO: Sunshine Coast Regional District

FOR: Watermain Upgrade 2023, North Pender Harbour, SCRD

THIS IS TO CERTIFY THAT INFORMATION: Construction Permit application dated April 14, 2023, Onsite Engineering Ltd drawing Sheet Number 723-9-021 to 023, 200-206 (all of Rev A) for North Pender Harbour Water Main Replacement

PREPARED AND SUBMITTED BY: Onsite Engineering Ltd., Abbotsford

PORTRAYING: proposed replacement of existing watermain and appurtenance for the water distribution system in the Panorama Drive area from Garden Bay Road, North Pender Harbour as shown in the drawings


and submitted in accordance with Section 7 of the Drinking Water Protection Act have been reviewed and the proposed work on the construction, alteration or extension may be commenced in accordance with the approved plans.

This document grants authorization under Section 7 (Construction permits and requirements for water supply systems) of the Drinking Water Protection Act only, and does not constitute permission or consent under any other Act or authority.

This permit is subject to the terms and conditions identified in the attached Schedule One.

July 14, 2025

DATE ISSUED



Chris Keung, P.Eng.
Public Health Engineer
Vancouver Coastal Health

Schedule One - Water Supply System Construction Permit No. VCH – 25 – 649

The following Terms and Conditions form part of this Water Supply System Construction Permit:

1. When abandoning sections of watermains, length of deadend pipes on the operational watermain must be kept to the minimum, by making the cuts as close to the operational watermain as possible. The cut ends on the operational watermains must be capped and sealed (and not just closed off by valves).
2. Blow-down chambers should have water tight hatch covers
3. This Permit applies specifically to the works as herein approved. Any subsequent changes to the design require the submission of amended drawings to the Public Health Engineer and approval before installation of the amended works. Approval of the works in this Permit is not to be construed as approval of any existing works in the remainder of the water system.
4. It is the responsibility of the Owner of the water system to ensure that, following completion of construction or repair, all new works are adequately disinfected in accordance with the appropriate AWWA standard or equivalent. After disinfection, the water must be tested for bacteriological quality by a lab accredited by the BC Provincial Health Officer and satisfactory results obtained before the works are placed in service. A copy of the final test results is to be sent to the Drinking Water Officer.