



SUNSHINE COAST REGIONAL DISTRICT

Question and Answers # 6

Request for Proposal No. 2536503

Watermain Replacement North Pender Harbour

Date: November 27 , 2025

Item No.1

Question: Can you please provide the Regional District specs specifically W1F and W1s

Answer: We believe you are requesting drawing numbers W2E and W2F, please see amendment no.4.

Item No.2

Question: Can you please clarify if the watermain line items such as a new meter box and setter are being provided by the Contractor or the Regional District.

Answer: New meter box and setter to be provided by the Contractor. For additional meter box information, please see Q&A 1 Item No 17.

Item No.3

Question: Can we please request a one (1) week extension to the closing date and time.

Answer: No, unfortunately we will not be able to accommodate an extension.

Item No.4

Question: Could you please provide more details/specs for the water meter and setter?

Answer: Please see W1, IFT Drawings and Item No 1 above (W2E and W2F) for additional details.

Item No.5

Question: Could you confirm if the "Cap" line item is to include CDF abandonment of existing mains?

Answer: CDF fill is not being considered at this time.

Item No.6

Question: Could you confirm if the Regional District will accept alternate backfill and subbase materials as 3" SGSB and 3" pit run are not available in local quarries?

Answer: All backfill and subbase materials to meet MOTT specifications as per the drawings.