



## SUNSHINE COAST REGIONAL DISTRICT

Question and Answers #1

Request for Proposal No. 2634501

Float Replacement Hopkins Landing

**Date: April 27, 2026**

### **Item No.1**

**Question:** Could you please confirm the weight of the existing ramp? This information will help us ensure proper planning and allocation.

**Answer:** The gangway is estimated to weigh approximately 1.4-1.6 tonnes; however, the Contractor is responsible for verifying the actual weight.

---