



## SUNSHINE COAST REGIONAL DISTRICT

Question and Answers #1

Request for Proposal No. 2435204

Contact Water Pond Relocation at the Sechelt Landfill

**Date: September 10, 2024**

### **Item No.1 Specifications Section 31 23 11 Fill and Schedule of Prices**

**Question:** For the compacted clay liner, would it be possible for Geosynthetic Clay liner to be an approved alternative?

**Answer:** No, a Geosynthetic Clay liner (GCL) is not acceptable as an alternative to compacted clay liner as the GCL would be damaged during pond maintenance involving excavator removal of accumulated deposits.

---