



SUNSHINE COAST REGIONAL DISTRICT

Question and Answers #1
Request for Proposal No. 2437022
Well Improvements at Chaster Well

Date: September 26, 2024

Item No.1

Question: Inside the vault there is a clear tube where does it go?

Answer: The clear tube connects to the dosing pump which is located inside the pump house.

Item No.2

Question: Does the watermain connect to another structure / building nearby?

Answer: No, it does not.

Item No.3

Question: Can you review your requirement for the \$10,000,000.00 in automobile insurance from ICBC?

Answer: Please see Addendum No.1

Item No.4

Question: The existing sodium line is within the existing vault, as everything is being lifted, the line will require some protection from the weather such as an insulated box or a building for the whole area to protect the infrastructure from freezing. Do you have a method that is preferred?

Answer: The Proponent will need to propose a solution to this problem, please note that this area is on a right of way so the existing footprint of the facility needs to remain the same; some of the equipment will still be under ground the Contractor could use this area to house the equipment.

Item No.5

Question: The existing equipment is being lifted up, approximately how high is it being lift up from the existing base.

Answer: Please refer to Appendix 2 Drawings for exact measurements.

Item No.6

Question: How much water does this well produce?

Answer: The station has a maximum supply capacity of 17L/s.

Item No.7

Question: Do you have a timeframe for when this work will be completed?

Answer: The Regional District's intent is to present the contract award to the Regional District Board on November 28, 2024; Chaster well needs to be available for use and operational between May 15 and October 15 so the work must be completed outside this timeframe. The Proponent should provide a schedule for them to complete the work.
