



SUNSHINE COAST REGIONAL DISTRICT

Question and Answers #4

Request for Proposal No. 2437022

Well Improvements at Chaster Well

Date: October 9, 2024

Item No.1

Question: In Appendix 1 (Specifications) refers to 4-hour tests conducted before and after Well development. When do you envision the 72-hour test being conducted?

Answer: After the reconditioning/development to confirm a final sustainable yield of the Well.

Item No.2

Question: Could you provide some background as to why the existing pump failed?

Answer: Age 11+ years old and nature of the old existing infrastructure.
